Page 1

Town: CONWAY

Thursday, August 5 2004

EPA Id:	NH 0512190	System Name:	BROOK VIEW VILLAGE			Pop Served: 40
PWS Type:	COMMUNITY SYSTEM	·				·
Vio Id Co	ntaminant		Violation Description	MCL	Result Mg/I	Awareness Comp Achved
300002 FL	UORIDES		MCL VIOLATION	4.00000	3.40000000	01/16/2004
EPA Id:	NH 0512010	System Name:	C W C /BIRCH HILL EAST			Pop Served: 315
PWS Type:	COMMUNITY SYSTEM					
Vio Id Co	ntaminant		Violation Description	MCL	Result Mg/l	Awareness Comp Achved
300007 FL	UORIDES		MCL VIOLATION	4.00000	2.90000000	01/16/2004
EPA Id:	NH 0512020	System Name:	C W C /BIRCH HILL WEST			Pop Served: 113
PWS Type:	COMMUNITY SYSTEM					
Vio Id Co	ntaminant		Violation Description	MCL	Result Mg/l	Awareness Comp Achved
300003 FL	UORIDES		MCL VIOLATION	4.00000	2.80000000	01/16/2004
EPA Id:	NH 0512280	System Name:	C W C/BIRCH HILL EAST II			Pop Served: 55
PWS Type:	COMMUNITY SYSTEM					
Vio Id Co	ntaminant		Violation Description	MCL	Result Mg/l	Awareness Comp Achved
300006 FL	UORIDES		MCL VIOLATION	4.00000	2.70000000	01/16/2004
EPA Id:	NH 0512030	System Name:	CATHEDRAL LEDGE			Pop Served: 150
PWS Type:	COMMUNITY SYSTEM					
Vio Id Co	ntaminant		Violation Description	MCL	Result Mg/I	Awareness Comp Achved
300011 FL	UORIDES		MCL VIOLATION	4.00000	3.00000000	01/16/2004
EPA Id:	NH 0512200	System Name:	CEDAR CREEK			Pop Served: 105
PWS Type:	COMMUNITY SYSTEM					
Vio Id Co	ntaminant		Violation Description	MCL	Result Mg/I	Awareness Comp Achved
300021 FL	UORIDES		MCL VIOLATION	4.00000	3.20000000	03/01/2004
EPA Id:	NH 0516030	System Name:	CONWAY MUNICIPAL CENTER			Pop Served: 36
PWS Type:	NON-TRANSIENT NON-C	OMMUNITY				

Thursday, August 5 2004 2003 MCL and Treatment Technique Violations Page 2

Town: CONWAY

System Name: Pop Served: 36 EPA Id: NH 0516030 **CONWAY MUNICIPAL CENTER**

PWS	Type: NON-TRANSIENT NON-CO	MMUNITY				
Vio Id	Contaminant		Violation Description	MCL	Result Mg/l	Awareness Comp Achved
400015	FLUORIDES		MCL VIOLATION	4.00000	4.10000000	11/06/2003
E	PA Id: NH 0511010	System Name:	CONWAY VILLAGE FIRE DISTRICT			Pop Served: 1937
PWS	Type: COMMUNITY SYSTEM					
Vio Id	Contaminant		Violation Description	MCL	Result Mg/I	Awareness Comp Achved
300016	COLIFORM (TOTAL COLIFORM	(I RULE)	NON-ACUTE MCL VIOLATION /STANDARD		Present	09/04/2003 03/04/2004
E	PA ld: NH 0512260	System Name:	DAVIS HILL			Pop Served: 75
PWS	Type: COMMUNITY SYSTEM					
Vio Id	Contaminant		Violation Description	MCL	Result Mg/I	Awareness Comp Achved
300003	FLUORIDES		MCL VIOLATION	4.00000	2.30000000	01/16/2004
EPA Id: NH 0512150 System Name:		System Name:	DEERBROOK CONDOS			Pop Served: 68
PWS	Type: COMMUNITY SYSTEM					
Vio Id	Contaminant		Violation Description	MCL	Result Mg/I	Awareness Comp Achved
300002	FLUORIDES		MCL VIOLATION	4.00000	2.20000000	01/16/2004
El	PA Id: NH 0512050	System Name:	ECHO LAKE WOODS			Pop Served: 112
PWS	Type: COMMUNITY SYSTEM					
Vio Id	Contaminant		Violation Description	MCL	Result Mg/I	Awareness Comp Achved
300003	FLUORIDES		MCL VIOLATION	4.00000	3.30000000	01/16/2004
EI	PA Id: NH 0512060	System Name:	FOREST EDGE			Pop Served: 118
PWS	Type: COMMUNITY SYSTEM					
Vio Id	Contaminant		Violation Description	MCL	Result Mg/l	Awareness Comp Achved

4.00000

2.20000000

01/16/2004

Pop Served: 45

MCL VIOLATION

FOREST PARK VILLAGE

System Name:

PWS Type: COMMUNITY SYSTEM

FLUORIDES

EPA ld: NH 0512070

300018

Town: CONWAY

Vio Id

300012

Contaminant

FLUORIDES

EP	A ld: NH 0512070	System Name:	FOREST PARK VILLAGE			Pop Served: 45
PWS T	ype: COMMUNITY SYSTEM					
Vio Id	Contaminant		Violation Description	MCL	Result Mg/I	Awareness Comp Achved
300020	FLUORIDES		MCL VIOLATION	4.00000	2.60000000	01/16/2004
EP	A ld: NH 0512230	System Name:	MELODY PINES CONDOS			Pop Served: 125
PWS T	ype: COMMUNITY SYSTEM					
Vio Id	Contaminant		Violation Description	MCL	Result Mg/l	Awareness Comp Achved
300003	FLUORIDES		MCL VIOLATION	4.00000	3.70000000	01/16/2004
EP	A ld: NH 0512110	System Name:	NORTH PINES ASSOC			Pop Served: 67
PWS T	ype: COMMUNITY SYSTEM					
Vio Id	Contaminant		Violation Description	MCL	Result Mg/I	Awareness Comp Achved
300001	FLUORIDES		MCL VIOLATION	4.00000	2.20000000	01/16/2004
EP	A ld: NH 0512180	System Name:	SACO PINES			Pop Served: 50
PWS T	ype: COMMUNITY SYSTEM					
Vio Id	Contaminant		Violation Description	MCL	Result Mg/l	Awareness Comp Achved
300017	FLUORIDES		MCL VIOLATION	4.00000	2.30000000	01/16/2004
EP	A ld: NH 0512140	System Name:	SOUTH PINES			Pop Served: 70
PWS T	ype: COMMUNITY SYSTEM					

MCL

4.00000

Result Mg/I

2.90000000

Awareness Comp Achved

01/16/2004

Violation Description

MCL VIOLATION

7, 3

Description of Data Reported

PWS: Public Water System

Town: Town, city or unincorporated place - political boundary in which the system is located.

EPA Id: Also known as PWS Id. State and Federal number assigned to track PWS.

System Name: Legal name of PWS.

Pop Served: The population served by PWS.

PWS Type: Type of PWS based on Federal Definition.

Community: Residential system capable of serving at least 25 residents.

Non-Community Non-Transient: Non-residential system capable of serving at least 25 of the same people 6 months a year.

Non-Community Transient: A system capable of serving water to at least 25 people 60 days a year.

Viol Id: The Federal Fiscal Year plus the violation identifier assigned by Environmental Services.

Contaminant: The contaminant and/or rule of which the PWS is in violation.

Violation Description: The type of violation.

Awareness: Date the state became aware of the MCL or TT violation.

MCL (Maximum Contaminant Level): The highest amount of a contaminant that the EPA allows in drinking water. MCLs are defined in milligrams per liter (Mg/I) (parts per million) unlessotherwise specified.

Result: Chemical Monitoring (Phase I, II, IIB and V) Rules: The analytical result(s) that caused the MCL violation.

Bacteria (Total Coliform) Rule: PRESENT indicates an MCL violation. ie., coliform is present.

Lead and Copper Rule and Surface Water Treatment Rule: TT (Treatment Technique) Violation or failure to meet operational and/or system requirements under the rule.

Comp Achved: The date the PWS returned to compliance for the violation.

* The violations listed are based on both Env-WS300 "NH Drinking Water Rules" and 40 CFR Part 141-143 "National Primary Drinking Water Regulations, Seconday Drinking Water Regulations"

--- END OF REPORT ---